


1111 Compliance for inorganic substances (%)

Compliance for inorganic substances = $\sum (\text{Maximum concentration of each inorganic substance} / \text{Target concentration of each inorganic substance}) / 6 \times 100 (\%)$



[Percentile Value] Water Utility

Fiscal year

F.Y.	95%	75%	50%	25%	5%
2008	30	19	15	11	8
2009	29	19	14	11	7
2010	30	19	14	11	7
2011	28	17	12	9	6
2012	26	17	12	9	6

Inorganic Substances	Water Quality Std.
Aluminum and its compounds	0.2mg/L
Chloride ion	200mg/L
Calcium & Magnesium (Solidity)	300mg/L
Iron and its compounds	0.3mg/L
Manganese and its compounds	0.05mg/L
Sodium and its compounds	200mg/L

Population supplied (F.Y.2012)

People	95%	75%	50%	25%	5%
<=1	25	14	10	8	5
1-3	24	16	11	9	6
3-10	28	18	13	10	7
10-50	27	19	16	12	9
50<	24	17	15	12	9

× 10,000people

[Scatter Plot]

